



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY SERVICES



Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/257/2024-25

DATE: 27/11/2024

FIRE & EMERGENCY SERVICES



To,
M/s-En Con Project Consultants,
G-7, 8, "D" Wing, Sethi Palace,
Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar-401 202.

Sub:-"Final No Objection Certificate" of School & Auditorium Building No.4 & CBSE Secondary School Building No.5 located on land bearing S.No.30/18(Pt), 30/19, 32/2/A, 32/3, 32/4(Pt), 33/8, 33/9, 33/10, 33/11, 33/12, 33/13, 33/14, 33/15, 33/16, 33/17, 33/18, 34/1, 34/2, 35/1, 36/1/1, 36/3, 36/4, 36/5, 36/6, 36/7, 36/8, 36/9, 37/1, 37/2, 37/3 of Village:Manickpur, Tal:Vasai, Dist: Palghar.

- Ref:- 1) An application received by M/s-En Con Project Consultants, Dated:09/10/2024. (VP - 0446)
2) An application received by Developer M/s-Canossa Society, Dated:09/10/2024.
3) Total Construction area certificate for M/s-En Con Project Consultants, Dated:09/10/2024.
4) Work Completed certificate by M/s-En Con Project Consultants, Dated:09/10/2024
5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/199/2022-23, Dated:06/06/2022.
6) Certificate from License Agency M/s-Ronak Fire Industries, Dated:28/06/2024. (Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated:11/06/2024.
8) AMC Certificate by M/s-Canossa Society, Dated:14/07/2024.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:23/10/2024.
10) Structure Stability Certificate for M/s-G.R. Consultants, Dated:11/07/2024.
11) CC issued by VVCMC/TP/CC/NP-0446/276/2022-23, Dated:07/09/2022.
12) Submitted Electric Certificate M/s-V.V.Electrical & Decorator, Dated:10/07/2024.
13) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:03/09/2024.
14) C.F.O. site visit Dated:23/10/2024.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your School & Auditorium Building No. 4 as Ground + Mezzanine + 2nd floor In 13.50mtr Height & CBSE Secondary School Building No. 5 as Ground + 3rd floor In 14.70mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Ronak Fire Industries, bearing License No. MFS-LA/RF-267, MFS-LA/RD-250 & has submitted Certificate on 28/06/2024 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Bldg No. 4 - 2447.74sq.mtrs & Bldg No. 5 - 2296.81sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 23/10/2024 for inspection from the point of view of fire prevention & protection provided by "M/s-Canossa Society" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) GIC Class Pipe welding of GI Elbow fitting and Painting - 01 Nos.
- B) Single Hydrant Valve - 14 Nos.
- C) Two Way Inlet - 01 Nos.
- D) Butterfly Valve 100mm - 06 Nos.
- E) Butterfly Valve 80mm - 05 Nos.
- F) NRV 80mm - 01 Nos.
- G) NRV 100mm - 02 Nos.
- H) GM Air Release Valve - 02 Nos.


PRINCIPAL
Canossa School CBSE
Manickpur, Vasai Road,
Dist. Palghar - 401202

- I) Hose Reel Drum - 06 Nos.
- J) MS Single Door Hose Box - 14 Nos.
- K) Pressure Gauge - 02 Nos.
- L) Main Pump (1620lpm) - 01 Nos.
- M) Stand by Pump (1620lpm) - 01 Nos.
- N) Jockey Pump (180lpm) - 01 Nos.
- O) Main Fire Control Panel - 01 Nos.
- P) ABC Type Fire Extinguisher (06 Kg) - 26 Nos.
- Q) Fire Bucket - 04 Nos.
- R) Starter - 01 Nos.
- S) Sprinkler Pendant Type - 85 Nos.
- T) 04 Zone Fire Alarm Panel Board - 01 Nos.
- U) Manual Call Point - 04 Nos.
- V) Hooter - 04 Nos.
- W) Smoke Detector - 02 Nos.

This No Objection certificate shall be treated valid for the period of one year from the date of issue It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Capitation & scrutiny Fees of Rs.6,00,000/- vide Receipt No.30749, Book No.308, DD.No.749044 (Canara Bank), Dated:04/05/2022.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building if any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Canossa Society.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.


PRINCIPAL
Canossa School CBSE
Manickpur, Vasai Road,
Dist. Palghar - 401202